



QUALITY TEST CERTIFICATION

Alloy No: C12200 Temper: O60

Dimension: $\Phi 3/8$ "x 0.55 x 15M Specification: ASTM B280

Test Items		Normal Value	Test Value	
			Sample 1	Result
Size	(OD) mm	9.52± 0.05	9.555	Pass
	(wall thickness)mm	0.55(-0.06~+0.02)	0.50-0.55	Pass
(Grain Size) mm		≥ 0.040	0.040	Pass
(Clearness) mg/m ²		≤ 38	19.55	Pass
Mechanical Property	(Tensile Strength) Mpa	≥ 205	239	Pass
	(Elongation) %	≥ 40	46	Pass
(Expansion Test) α=60 ° D=1.4D		No crack when vision	Pass	Pass
Eddy Current Test mm		0Point	Pass	Pass
Surface		Conform To		
Packing Requirement		Conform To		
Marking		Conform To		
% Chemical Composition	Cu	≥99.90	99.96	Pass
	P	0.015-0.040	0.0359	Pass
RESULT	PASS			

This Product is Certified to be in accordance with the specification.